Installation Instructions

**Touch sensor simple Touch sensor double** Touch sensor fourfold Multifunction touch sensor Light scene touch sensor

## GIRA

Order no.: 0551 4x, 0881 xx Order no.: 0552 4x, 0882 xx Order no.: 0884 xx Order no.: 0885 xx Order no.: 0888 xx

## System information

This device is a product of the Instabus EIB-system and complies with EIBA directives.

Detailed technical knowledge obtained in Instabustraining courses is a prerequisite for proper understanding.

Functionality of this device is depending on the software. Detailed information on loadable software and attainable functionality may be taken from the manufacturer's product database.


Planning, installation and commissioning of the unit is done by means of EIBA certified software.

## Function

When depressed, pushbutton sensors transmit data telegrams on the Instabus EIB triggering switching, dimming or shutter control functions in the respective actuators, recalling or storing lightscapes and set dimming, brightness or temperature values.

## Installation Instructions

Attaching user module ① to flush-mounted bus coupler 2 connects them via user interface 3.



The current product database and technical descriptions can be found on the Internet at www.gira.de.

## ✓! Safety instructions

Attention: Electrical equipment must be installed and fitted by qualified electricians only.

Non-observance of the safety instructions may cause fire or other hazards.

Installation Instructions

# GIRA

## **Specifications**

Info

Supply Instabus EIB:	21 – 32 V DC via bus coupling unit (BCU)
Connection Instabus:	Connecting terminal and branch joint
Physical external interface:	Attach to BCU
Ambient temperature:	-5 °C to +45 °C
Storage/transport temperature:	-25 °C to +70 °C
Type of protection:	IP 20
Protection class:	III

## Acceptance of guarantee

We accept the guarantee in accordance with the corresponding legal provisions.

Please return the unit postage paid to our central service department giving a brief description of the fault:

Gira Giersiepen GmbH & Co. KG **Service Center** Dahlienstrasse 12 D-42477 Radevormwald

CE The CE sign is a free trade sign addressed exclusively to the authorities and does not include any warranty of any properties.

Gira Giersiepen GmbH & Co. KG Postfach 1220 D-42461 Radevormwald

Telefon: +49 / 21 95 / 602 - 0 Telefax: +49 / 21 95 / 602 - 339 Internet: www.gira.de